

Cr. Villaviciosa de Odón a Móstoles (M-856) Km. 1,5 Móstoles - 28935 (Madrid) -ESPAÑA (SPAIN)

Phone: 916 169 710 Fax: 916 162 372

comercial@ceis.es

Report Ref nº: CEL-0464/20-1

Date of issue: 13/08/2020

TEST REPORT

Requester's data

Client: DELVALLE GLOBAL SOLUTIONS, S.L.U. Fabricante: DELVALLE GLOBAL SOLUTIONS, S.L.U.

Manufacturer

Address: OYÓN PASO EL PRAO Nº6 (ALAVA) - ESPAÑA Address: OYÓN PASO EL PRAO Nº6 (ALAVA) - ESPAÑA

Samples reception: 13/07/2020 Licensee: ----

Product: Junction boxes Geo Fire

Performance: Test for resistance to fire of unprotected small cables for use in emergency circuits according UNE 50200; PH120 120

mın

Scope: 3x Junction boxes galvanized painted steel and stainless steel

Refer.Client:Geo -120x120x80; Geo -120x160x80; Geo -250x400x150; Test period: 29/07/2020-30/07/2020

RESULTS

All tested samples COMPLY in accordance with this report test results. Therefore, applicable specification conformity criteria, are defined in paragraph Stating Compliance and Applied Standard.

General dispositions:

The results contained in this report were obtained using only the sample that was the object of this study, at he moment and in the conditions in which the measurements were taken. This is a brief report. The laboratory keeps detailed information on the tests (for 5 years) and control samples to be made available to the customer upon request.

This report can only be reproduced in its entirety, the partial reproduction of this report is prohibited without the express permission of the laboratory. The uncertainties associated with the measures included in this report are estimated and available to the customer.

Report Revised by: Project Manager

This report is secure and protected against subsequent changes of its signature. To check the signed version and the original, coincidences, click on the alert icon that appears above the digital signature; you will be able to see the only version certified by the report signature.

ceis wishes to thank you for the confidence shown by utilizing our services, and we hope that the services we provided were in accordance with your needs and requirements.

At ceis, we believe in continual improvement, so we welcome any suggestions for improve that you feel is of value your company. Please send your comments to calidad@ceis.es

























